


COMMERCIAL TANK

ABOVE GROUND OR UNDERGROUND TANK
Application covers temporary or permanent tanks

City of Aurora
Development Services Department
Division of Building and Permits
77 S Broadway
Aurora, IL 60505



APPLICATION #: _____

Total Fees: _____ Submittal Date: _____
Online Portal: <https://auro-trk.aspgov.com/etrakit/> Phone: 630.256.3130 Website: www.aurora-il.org

Property Address: _____ Unit/Suite #: _____

Owner Information (all fields required)

Additional Contact Info Applicant Tenant Property Mngr

Name: _____

Name: _____

Address: _____

Address: _____

Phone: _____

Phone: _____

Email: _____

Email: _____

ACKNOWLEDGEMENT OF APPLICATION ONLY

This is an application only. Completion of this application does NOT entitle the commencement of construction. I, (the applicant) agree to conform to all applicable laws of the City of Aurora. I also agree that all work performed will be in accordance with the plans and specifications as set forth in the approved permit. I understand that the approval of this application and issuance of a permit does not preclude the need to comply with all applicable laws and ordinances. I agree to hold harmless and indemnify the City of Aurora for any claim against the City as the result of any act of commission or omission by or on behalf of the undersigned, his/her agent, principle, contractor, subcontractor or supplier. I the undersigned am the Owner or a duly contracted representative of the owner of said property. As part of this application process, I affirm that all the information herein is true and correct to the best of my knowledge. I authorize the City of Aurora to make any reasonable inspections of the property as part of the application and permit process.

Owner Contractor Representative Role: _____

Name: _____ Signature: _____

DESCRIPTION OF WORK

COMMERCIAL TANK INFORMATION CHECKLIST – GENERAL INFORMATION

Tank Location: Above Ground Below Grade Timeframe: Permanent Temporary

Storage Size in Gallons: _____ Product to be Stored: _____

APPLICATION SUBMITTAL REQUIREMENTS

- o Drawings indicating scope of work, specifications of tank being installed, and site plan with requested locations.
 - o Provide a site plan and drawing that depicts the actual location of the tank on site.
 - o Provide Safety Data Sheets and plan for NFPA 704 compliance.
 - o Provide a dimensional drawing that identifies the locations, dimensions, and associated information for the barrier protection and the bollards.
- o The tank and associated equipment must comply with Chapter 57 of the IFC.
- o Placards shall be applied in accordance with NFPA 704 and Chapter 57 of the IFC.
 - o A description of the placard shall be included in the submittal and the location shall be identified on plans.
- o Certified fire extinguishers are required in accordance with IFC 906.
- o Provide vehicle impact protection in accordance with the IFC Chapter 3 Section 312. The installation will be verified in the field for compliance.
 - o All liquid propane and associated regulators and piping that are exposed to vehicular traffic, or located within 25 ft. of a roadway or parking lot shall be protected from vehicle damage.
 - o Vehicle impact protection shall consist of installation of posts constructed of steel not less than 4 in. in diameter and concrete filled and set not less than 36 in. deep in a concrete footing not less than 15 in. in diameter and spaced not more than 4 ft. between posts. Or provide a physical barrier a minimum of 36 in. high that can resist a force of 12,000 lbs. applied at a point 36 in. above the adjacent ground surface.
- o If the fuel storage exceeds 110 gallons, therefore a separate permit and inspections are required by the Illinois State Fire Marshal.
 - o A copy of that permit shall be provided to the City of Aurora, and every effort should be made to coordinate all inspections.
- o The storage of flammable and combustible liquids shall comply with chapter 57 of the 2024 International Fire Code.
 - o A separate permit from the Illinois State Fire Marshall shall be submitted with the application.
- o The storage of liquid propane gas shall comply with Chapter 61 of the 2024 International Fire Code.
 - o A separate permit from the Illinois State Fire Marshal is required for singular tanks of greater than 2,000 gallons capacity or multiple tanks with an aggregate capacity of 4,000 gallons or any size tank used to dispense liquid propane gas into smaller cylinders or vehicles.

Application Fee is due at time of submittal.

COST OF WORK: _____

APPLICABLE CODES

2024 NFPA 30
2022 NFPA 704
2022 NFPA 10

2023 NFPA 52
2023 NFPA 59
2024 NFPA 58

2024 International Building Code
2024 International Fire Code
[City of Aurora Ordinances](#)

TANK CONTRACTOR INFORMATION

GENERAL CONTRACTOR INFORMATION

City of Aurora Registration #: _____
Business Name: _____
Contact Name: _____
Address: _____
City, State, Zip: _____
Phone: _____
Email: _____

ELECTRICAL CONTRACTOR INFORMATION

City of Aurora Registration #: _____
Business Name: _____
Contact Name: _____
Address: _____
City, State, Zip: _____
Phone: _____
Email: _____